



Department of
Rehabilitation & Correction

Mike DeWine, Governor
Annette Chambers-Smith, Director

09/11/2019

Sheriff Dallas Baldwin
Franklin County Corrections Center I
370 S. Front Street
Columbus, OH 43215

RE: 2019 Annual Jail Inspection

Dear Sheriff Dallas Baldwin:

In accordance with Section 5120.10 of the Ohio Revised Code and Executive Order 92-03 of the Department of Rehabilitation and Correction, the Franklin County Corrections Center I, a full service jail, was inspected on 08/28/2019. The inspection was restricted to assessing compliance with a group of standards, selected from the Standards for Jails in Ohio promulgated by the Department of Rehabilitation and Correction. The group of standards being inspected focused on Reception & Release, Classification, Security, Housing, Sanitation and Environmental Conditions, Communication, Visitation, Medical and Mental Health Services, Food Service, Recreation and Programming, Inmate Discipline, Administrative Segregation, Grievance, Staffing, and Staff Training. The inspection consisted of this Inspector receiving and/or reviewing requested documentation and/or materials, touring selected areas of the jail, and having discussions with various jail staff.

The total actual general housing capacity for the Franklin County Corrections Center I is 643. On the date of the jail inspection, there were 484 inmates incarcerated in the Franklin County Corrections Center I. The Ohio Department of Rehabilitation and Correction recommended housing capacity for the jail is 402, which is based upon total available living space and other requirements. Officials should maintain prisoner counts within the Department's recommended capacity figure.

The Franklin County Corrections Center I (Full Service Jail) is in compliance with 109 standards, 53 "Essential", and 56 "Important".

5120:1-8-01 (A)(1); -01 (A)(3); -01 (A)(4); -01 (A)(7); -01 (A)(9); -01 (A)(12); -02 (B)(1); -02 (B)(2); -02 (B)(4); -02 (D); -03 (A)(1); -03 (A)(3); -03 (A)(4); -03 (A)(5); -03 (A)(6); -03 (A)(7); -03 (B)(2); -03 (B)(4); -03 (B)(5); -03 (B)(6); -03 (B)(7); -03 (B)(8); -03 (B)(9); -03 (B)(10)(a); -03 (B)(10)(b); -03 (B)(10)(c); -03 (B)(10)(d); -03 (B)(11)(b); -03 (B)(11)(c); -03 (B)(12); -03 (B)(15); -03 (B)(16); -03 (B)(17); -04 (C); -04 (D); -04 (E); -04 (F); -04 (J); -04 (K); -05 (A); -05 (B); -05 (C); -05 (E); -05 (H)(3); -05 (I); -05 (J); -05 (K); -05 (L); -05 (M); -05 (N); -05 (O); -05 (P); -05 (Q); -06 (B); -06 (C); -06 (G); -07 (A); -07 (D); -07 (E); -07 (H); -07 (I); -09 (A); -09 (B); -09 (C); -09 (D); -09 (E); -09 (F); -09 (G); -09 (H); -09 (J); -09 (K); -09 (M); -09 (N); -09 (P); -09 (Q); -09 (R); -09 (U); -09 (V); -09 (W); -09 (X); -10 (A); -10 (B); -10 (C); -10 (D); -10 (E); -10 (F); -10 (G)(1); -10 (G)(2); -11 (A); -11 (B); -11 (E); -12 (B); -12 (C); -12 (F); -12 (G); -12 (H); -15 (B); -15 (D); -15 (E); -16 (A); -17 (D); -17 (E); -17 (F); -17 (G); -18 (A); -18 (B); -18 (C); -18 (D); -18 (E);

The Franklin County Corrections Center I did not comply with 6 standards, 0 "Essential", and 6 "Important". This letter is intended to serve as a basis for developing plans of action for bringing the facility into compliance with the deficiencies noted during the inspection.

5120:1-8-04 (A) (4) Full service jails shall provide inmates with sufficient space. The jail shall maintain documentation regarding square footage and maximum occupancy figures for all housing and holding areas, and shall comply with the following minimum requirements: Dayspace: (Important) Thirty-five square feet per number of occupants occupying the dayspace at one time. Minimum size of one hundred five square feet.

Comments: The jail has exceeded the Bureau Recommended Capacity (BRC) for their facility and there is not the recommended amount of day space for each inmate.

5120:1-8-04 (B) (Important)) Seating shall be provided in holding areas, holding cells, housing cells, dormitories, dayrooms and eating areas for each inmate.

Comments: At the time of the inspection it was observed that inmates placed in cells are not provided with "proper seating". This is defined as actual seating designed for this purpose and does not include the floor or other areas not specifically designed for seating.

5120:1-8-04 (G) (Important) Shower facilities at a minimum of one operable shower for every twelve occupants. Water temperatures shall be controlled thermostatically in a range from one hundred five to one hundred twenty degrees Fahrenheit.

Comments: At the time of the inspection it was observed on the fifth floor dorm there were twenty beds and only one shower.

5120:1-8-04 (H) (Important) One operable wash basin with hot and cold potable water for every twelve occupants.

Comments: It was observed during the time of the inspection on the fifth floor dorm one wash basin in a twenty bed dorm.

5120:1-8-05 (G) The jails shall maintain documentation that the following standards are met with regard to interior lighting: (1) (Important) At least twenty foot-candles, measured thirty inches above the floor, in inmate reading areas.

Comments: At the time of inspection it was observed in multiple floors the lighting reading were under twenty candle power.

5120:1-8-05 (G) The jails shall maintain documentation that the following standards are met with regard to interior lighting: (2) (Important) At least fifteen foot-candles, measured thirty inches above the floor, in inmate accessible areas.

Comments: It was observed on this day on multiple floors the light reading in cells were less then fifteen candle power.

The Franklin County Corrections Center I is in compliance with 100% of the Essential Standards and at least 90% of the Important Standards meeting the requirements of a "Compliant Jail". It should be noted however; the jail did not comply with 6 of the Important Standards upon which the facility was inspected. This letter is intended to serve as a basis for developing plans of action for bringing the facility back into compliance with the remaining deficiencies noted during the inspection.

The Bureau of Adult Detention encourages the jail to correct the remaining deficiencies noted in the inspection report prior to the next annual jail inspection. Plan of Action forms are enclosed and can be submitted through the Ohio Jail Management System (OHJMS) at www.OHJMS.Intelligrants.com. Feel free to contact the Bureau if you need assistance or clarification in this effort. The Bureau remains available to discuss the aspects of this report and to provide reference materials or assistance as desired.

Sincerely,



Klinton Hill, State Jail Inspector
Bureau of Adult Detention
4545 Fisher Rd Suite D.
Columbus, Ohio 43228
Phone: (614) 374-3715
Email: klinton.hill@odrc.state.oh.us