



Department of
Rehabilitation & Correction

Mike DeWine, Governor
Annette Chambers-Smith, Director

01/13/2020

Sheriff Rob Streck
Montgomery County Jail
330 W Second Street
Dayton, OH 45422

RE: 2019 Annual Jail Inspection

Dear Sheriff Rob Streck:

In accordance with Section 5120.10 of the Ohio Revised Code and Executive Order 92-03 of the Department of Rehabilitation and Correction, the Montgomery County Jail, a full service jail, was inspected on 12/16/2019. The inspection was restricted to assessing compliance with a group of standards, selected from the Standards for Jails in Ohio promulgated by the Department of Rehabilitation and Correction. The group of standards being inspected focused on Reception & Release, Classification, Security, Housing, Sanitation and Environmental Conditions, Communication, Visitation, Medical and Mental Health Services, Food Service, Recreation and Programming, Inmate Discipline, Administrative Segregation, Grievance, Staffing, and Staff Training. The inspection consisted of this Inspector receiving and/or reviewing requested documentation and/or materials, touring selected areas of the jail, and having discussions with various jail staff.

The total actual general housing capacity for the Montgomery County Jail is 903. On the date of the jail inspection, there were 796 inmates incarcerated in the Montgomery County Jail. The Ohio Department of Rehabilitation and Correction recommended housing capacity for the jail is 443, which is based upon total available living space and other requirements. Officials should maintain prisoner counts within the Department's recommended capacity figure .

The Montgomery County Jail (Full Service Jail) is in compliance with 111 standards, 53 "Essential", and 58 "Important".

5120:1-8-01 (A)(1); -01 (A)(3); -01 (A)(4); -01 (A)(7); -01 (A)(9); -01 (A)(12); -02 (B)(1); -02 (B)(2); -02 (B)(4); -02 (D); -03 (A)(1); -03 (A)(3); -03 (A)(4); -03 (A)(5); -03 (A)(6); -03 (A)(7); -03 (B)(2); -03 (B)(4); -03 (B)(5); -03 (B)(6); -03 (B)(7); -03 (B)(8); -03 (B)(9); -03 (B)(10)(a); -03 (B)(10)(b); -03 (B)(10)(c); -03 (B)(10)(d); -03 (B)(11)(b); -03 (B)(11)(c); -03 (B)(12); -03 (B)(15); -03 (B)(16); -03 (B)(17); -04 (B); -04 (C); -04 (D); -04 (E); -04 (F); -04 (H); -04 (J); -04 (K); -05 (A); -05 (B); -05 (C); -05 (E); -05 (G)(2); -05 (I); -05 (J); -05 (K); -05 (L); -05 (M); -05 (N); -05 (O); -05 (P); -05 (Q); -06 (B); -06 (C); -06 (F); -06 (G); -07 (A); -07 (D); -07 (E); -07 (H); -07 (I); -09 (A); -09 (B); -09 (C); -09 (D); -09 (E); -09 (F); -09 (G); -09 (H); -09 (J); -09 (K); -09 (M); -09 (N); -09 (P); -09 (Q); -09 (R); -09 (U); -09 (V); -09 (W); -09 (X); -10 (A); -10 (B); -10 (C); -10 (D); -10 (E); -10 (F); -10 (G)(1); -10 (G)(2); -11 (A); -11 (B); -11 (E); -12 (C); -12 (F); -12 (G); -12 (H); -15 (B); -15 (D); -15 (E); -16 (A); -17 (D); -17 (E); -17 (F); -17 (G); -18 (A); -18 (B); -18 (C); -18 (D); -18 (E);

The Montgomery County Jail did not comply with 5 standards, 0 "Essential", and 5 "Important". This letter is intended to serve as a basis for developing plans of action for bringing the facility into compliance with the deficiencies noted during the inspection.

5120:1-8-04 (A) (4) Full service jails shall provide inmates with sufficient space. The jail shall maintain documentation regarding square footage and maximum occupancy figures for all housing and holding areas, and shall comply with the following minimum requirements: Day space: (Important) Thirty-five square feet per number of occupants occupying the day space at one time. Minimum size of one hundred five square feet.

Comments: On the day of the inspection the jail was well over the BRC. Jail officials should maintain jail population within the BRC.

5120:1-8-04 (G) (Important) Shower facilities at a minimum of one operable shower for every twelve occupants. Water temperatures shall be controlled thermostatically in a range from one hundred five to one hundred twenty degrees Fahrenheit.

Comments: On the day of the inspection the ratio was over for showers in the POD housing. Jail officials should maintain housing units with in the 1/12 ration for inmates.

5120:1-8-05 (G) The jails shall maintain documentation that the following standards are met with regard to interior lighting: (1) (Important) At least twenty foot-candles, measured thirty inches above the floor, in inmate reading areas.

Comments: On the day of the inspection some lights were out in the housing units affecting the lighting. Jail officials should maintain lighting to make sure inmates have adequate lighting.

5120:1-8-05 (H) The jail shall maintain documentation that the following standards are met with regard to bedding, linens and clothing: (3) (Important) Issued clothing shall be exchanged or laundered twice weekly. Arrangements are made to exchange or launder personal clothing and undergarments twice weekly;

Comments: On the day of the inspection personal clothing and undergarments were not being exchanged twice weekly. Jail officials need to up date schedule to meet policy and standard of personal laundry twice weekly.

5120:1-8-12 (B) (Important) There shall be a sanctioning schedule for rule violations. The jail administrator or designee shall approve any penalty exceeding suspension of rights or disciplinary isolation for more than one hundred twenty hours. The maximum sanction for rule violations shall be no more than sixty days for violations arising out of one incident. Continuous confinement for more than thirty days requires the review and approval of the jail administrator or designee.

Comments: On the day of the inspection nothing in policy states the maximum sanction for rule violations shall be no more than sixty days for violations arising out of one incident. Jail officials should update policy to meet all aspects of the standards.

The Montgomery County Jail is in compliance with 100% of the Essential Standards and at least 90% of the Important Standards meeting the requirements of a "Compliant Jail". It should be noted however; the jail did not comply with 5 of the Important Standards upon which the facility was inspected. This letter is intended to serve as a basis for developing plans of action for bringing the facility back into compliance with the remaining deficiencies noted during the inspection.

The Bureau of Adult Detention encourages the jail to correct the remaining deficiencies noted in the inspection report prior to the next annual jail inspection. Plan of Action forms are enclosed and can be submitted through the Ohio Jail Management System (OHJMS) at www.OHJMS.Intelligrants.com. Feel free to contact the Bureau if you need assistance or clarification in this effort. The Bureau remains available to discuss the aspects of this report and to provide reference materials or assistance as desired.

Sincerely,

Steve D. Holland

Stephen Holland, State Jail Inspector
Bureau of Adult Detention
1580 St Rt 56
London, Ohio 43140
Phone: (614) 981-2040
Email: stephen.holland@odrc.state.oh.us