



Department of
Rehabilitation & Correction

Mike DeWine, Governor
Annette Chambers-Smith, Director

11/21/2019

Chief Tony Coury
Zanesville City Jail
332 South Street
Zanesville, OH 43701

RE: 2019 Annual Jail Inspection

Dear Chief Tony Coury:

In accordance with Section 5120.10 of the Ohio Revised Code and Executive Order 92-03 of the Department of Rehabilitation and Correction, the Zanesville City Jail, a full service jail, was inspected on 11/18/2019. The inspection was restricted to assessing compliance with a group of standards, selected from the Standards for Jails in Ohio promulgated by the Department of Rehabilitation and Correction. The group of standards being inspected focused on Reception & Release, Classification, Security, Housing, Sanitation and Environmental Conditions, Communication, Visitation, Medical and Mental Health Services, Food Service, Recreation and Programming, Inmate Discipline, Administrative Segregation, Grievance, Staffing, and Staff Training. The inspection consisted of this Inspector receiving and/or reviewing requested documentation and/or materials, touring selected areas of the jail, and having discussions with various jail staff.

The total actual general housing capacity for the Zanesville City Jail is 56. On the date of the jail inspection, there were 52 inmates incarcerated in the Zanesville City Jail. The Ohio Department of Rehabilitation and Correction recommended housing capacity for the jail is 56, which is based upon total available living space and other requirements. Officials should maintain prisoner counts within the Department's recommended capacity figure .

The Zanesville City Jail (Full Service Jail) is in compliance with 113 standards, 52 "Essential", and 61 "Important".

5120:1-8-01 (A)(1); -01 (A)(3); -01 (A)(4); -01 (A)(7); -01 (A)(9); -01 (A)(12); -02 (B)(1); -02 (B)(2); -02 (B)(4); -02 (D); -03 (A)(1); -03 (A)(3); -03 (A)(4); -03 (A)(5); -03 (A)(6); -03 (A)(7); -03 (B)(2); -03 (B)(4); -03 (B)(5); -03 (B)(6); -03 (B)(7); -03 (B)(8); -03 (B)(9); -03 (B)(10)(a); -03 (B)(10)(b); -03 (B)(10)(c); -03 (B)(10)(d); -03 (B)(11)(b); -03 (B)(11)(c); -03 (B)(12); -03 (B)(15); -03 (B)(16); -03 (B)(17); -04 (A)(4); -04 (B); -04 (C); -04 (D); -04 (E); -04 (F); -04 (G); -04 (H); -04 (J); -04 (K); -05 (A); -05 (B); -05 (C); -05 (E); -05 (G)(1); -05 (G)(2); -05 (H)(3); -05 (I); -05 (J); -05 (K); -05 (L); -05 (M); -05 (N); -05 (O); -05 (P); -05 (Q); -06 (B); -06 (C); -06 (G); -07 (A); -07 (E); -07 (H); -07 (I); -09 (A); -09 (B); -09 (C); -09 (E); -09 (F); -09 (G); -09 (H); -09 (J); -09 (K); -09 (M); -09 (N); -09 (P); -09 (Q); -09 (R); -09 (U); -09 (V); -09 (W); -09 (X); -10 (A); -10 (B); -10 (C); -10 (D); -10 (E); -10 (F); -10 (G)(1); -10 (G)(2); -11 (A); -11 (B); -11 (E); -12 (B); -12 (C); -12 (F); -12 (G); -12 (H); -15 (B); -15 (D); -15 (E); -16 (A); -17 (D); -17 (E); -17 (F); -17 (G); -18 (A); -18 (B); -18 (C); -18 (D); -18 (E);

The Zanesville City Jail did not comply with 3 standards, 1 "Essential", and 2 "Important". This letter is intended to serve as a basis for developing plans of action for bringing the facility into compliance with the deficiencies noted during the inspection.

5120:1-8-05 (D) (Important) Regular maintenance and repairs shall occur.

Comments: At the time of inspection, several areas of the facility showed signs of disrepair and in need of repair that included ventilation grates that had been covered with debris, and ceiling tile that had been cracked and or removed. A recommendation from the annual health inspection report also indicated the dorm shower facilities were in disrepair; floor tiles, painted walls and damaged shower curtains. Jail administration indicated the floor tiles, showers, wall paint and ceilings on the 3rd floor are all in the planning stages. Additionally, the Safety Director for the City of Zanesville is in the process of preparing a RFQ to get a company in to prepare for the project to correct those deficiencies.

5120:1-8-07 (D) (Important) Visitors shall register upon entry into the jail. The registry shall include the date, visitor names, inmate visited and length of the visit.

Comments: At the time of inspection, Jail administration providing supporting documentation that did not evidence compliance with all aspects of the standard.

5120:1-8-09 (D) (Essential) Health appraisal. Within fourteen days, a licensed nurse, physician, physician's assistant, EMT or paramedic shall complete a health appraisal to determine the medical and mental health condition for each inmate in custody. Such appraisal shall at least include the following:

- (1) Review of receiving screen.
- (2) Collection of additional data to complete the medical, dental and mental health history.
- (3) Laboratory and/or diagnostic tests to detect tuberculosis and other suspected communicable diseases as designated by the health authority.
- (4) Recording the height, weight, pulse, blood pressure and temperature.
- (5) Medical examination as determined by the examiner.
- (6) Mental health assessment.
- (7) Initiation of therapy when determined necessary by the examiner.
- (8) Development and implementation of a treatment plan.
- (9) Other test and examination as determined by the examiner or health authority.

Comments: At the time of inspection, Jail administration as well as medical notified this Bureau that the Zanesville City Jail does not conduct TB laboratory or diagnostics tests to detect tuberculosis on each offender brought into the facility .

Plan of action forms are enclosed. Completed form(s) and/or corrective materials addressing the noted deficiencies must be completed and submitted through the Ohio Jail Management System (OHJMS) at www.OHJMS.Intelligrants.com within 45 days of receipt of this correspondence. Please feel free to contact the Bureau if you need assistance or clarification in this effort. The Bureau remains available to discuss the aspects of this report or to provide reference materials or assistance as desired.

Sincerely,



David Hicks, State Jail Inspector
Bureau of Adult Detention
1005 E. State St
Athens, Ohio 45701
Phone: (740) 593-3361
Email: david.hicks@odrc.state.oh.us